

**GRACE**

**Grace Construction Products**

W.R. Grace & Co.-Conn.  
William A. Dempster III  
62 Whittemore Avenue  
Cambridge, Mass. 02140-1692  
Phone: (617) 498-4870  
Fax: (617) 498-4419  
william.a.dempster.iii@grace.com

March 3, 2004

Mr. Cole Stanton  
Fiberlock Technologies, Inc.  
150 Dascomb Road  
Andover, MA 01810

Reference: ABC Encapsulant

Dear Mr. Stanton:

The use of ABC Encapsulant as a surface sealer for Monokote fireproofing is permitted under the following conditions:

- The flame spread index is less than 200 and the smoke development index is less than 450 as tested in accordance with ASTM E84/ UL723. This is detailed in the UL Fire Resistance Directory.
- The ABC Encapsulant material does not saturate the underlying Monokote fireproofing material.

I trust this information is sufficient. If you have any additional questions, please feel free to call me.

Regards



William A. Dempster III  
Technical Service Manager  
Grace Fire Protection Products

