

# HENRY

January 21, 1992

Fiberlock Technologies, Inc.  
630 Putnam Avenue  
Cambridge, MA 02139-0432  
Attn: Mark O' Connor

Dear Mark,

We have finished evaluating your Fiberset FT and ABC sealers with a variety of our adhesives and our results are below.

HENRY 251 and 356 Flooring Adhesives showed excellent bond strength to both sealers mentioned above when applied according to your directions. Because of these results our adhesives can be used over these sealers to install floor coverings. When our adhesives are used over sealers please remember to allow for longer dry time due to the sealed substrate.

While our Acoustical Adhesives (137 & 237) showed very good adhesion to both of your sealers ( both passed hang weight specifications) we cannot warranty our adhesives over sealers when installing ceiling tiles. Because of the liability involved with this type of application we cannot control the installation of the sealer to the ceiling.



Wally Giambastiani  
Product Development Manager  
Floor & Construction Adhesives

CORPORATE OFFICE: 5608 Soto St., Huntington Park, CA 90255 • (213) 583-4961 • FAX (213) 582-8451

MANUFACTURING PLANTS:

5920 Alamo Street, Maywood, CA 90270 • (213) 583-4961 • FAX (213) 771-6188  
210 W. Taft Avenue, Orange, CA 92667 • (714) 282-1240 • FAX (714) 974-6133  
350 S. Industrial Park Drive • P.O. Box 829 • Dallas, GA 30132 • (404) 445-5377  
3233 W. 36th Street, Chicago, IL 60632 • (312) 254-3510 • FAX (312) 254-7624  
Foot of Whitehead Avenue, South River, NJ 08882 • (201) 254-2424 • FAX (201) 254-8683  
520 W. 3rd Street, Dover, OH 44622 • (216) 343-4535 • FAX (216) 343-6387  
1101 Avenue G East, Arlington, TX 76011 • (817) 649-8070 • FAX (817) 633-4408